

In accordance with REACH Regulation EC No. 1907/2006

Document:	SDS 01
Issue No:	6
Issue Date:	16-May-2014
Page	1 of 11

SECTION 1: IDENTIFICATION OF THE PRODUCT AND OF THE MANUFACTURER/SUPPLIER

1.1	Product Identifier:	Valve Regulated Lead-Acid (VRLA) Industrial Battery
	Classification:	Battery, wet, non-spillable, electric storage Substance classification: UN 2800
	Product Codes:	EN & ENL, NP, NPC, NPH, NPL, NPW, RE, REC, REW, SWL, TEV, FXH, UXH, UXL, Yucel, YPC and YFT Series of Industrial VRLA Batteries
1.2	Relevant Identified Uses Of The Product And Uses Advised Against	Relevant identified uses: Standby: Telecoms; UPS; alarm and security systems; emergency lighting; utility switching Cyclic: Golf Trolleys, portable tools, portable lighting, wheelchairs, remote telemetry Energy storage: Photovoltaic energy systems (PVES); wind turbines
		Uses advised against: Automotive, commercial, and agricultural SLi applications Reason why uses advised against: High starting and ignition current demands beyond the design of internal and external current carrying components
1.3	Details Of The Supplier Of The Safety Date Sheet	
	-	
	National Contacts:	
.4	Emergency telephone number:	



In accordance with REACH Regulation EC No. 1907/2006

	<u> </u>
Document:	SDS 01
Issue No:	6
Issue Date:	16-May-2014
Page	2 of 11

SECTION 2: HAZARDS IDENTIFICATION

VRLA Battery	Mechanical	VRLA Batteries can be heavy. Correct manual handling techniques and/or mechanical lifting aides (e.g. Fork Lift Truck) must be used.
	Electrical	VRLA Batteries can contain large amounts of electrical energy which can give very high discharge currents and severe electrical shock if the terminals are short circuited.
·	Chemical	The VRLA Battery presents no chemical hazards during the normal operation provided the recommendations for handling, storage, transport and usage are observed. VRLA Batteries emit hydrogen gas which is highly flammable and will form explosive mixtures in air from approx. 4% to 76%. This can be ignited by a spark at any voltage, naked flames or other sources of ignition. If the battery is broken and the internal components exposed, hazards may exist which require careful attention.
Plate Grids and	Metallic Lead.	Lead alloys and Lead inorganic compounds:
Active materials	Lead poisoning is usually caused by inhalation of minute particles of Lead furne and dust, which absorbed by the blood stream from the lungs and deposited in the bone marrow. Lead is only slowly released from the bones and thus has an accumulative effect causing chroni poisoning. TOXIC by ingestion or inhalation of dust, vapour or furne May cause harm to the unborn child Harmful by inhalation and if swallowed Danger of cumulative effects	
Battery Electrolyte	olyte Severe IRRITATION and DAMAGE to Internal tissues if swallowed, IRRITATION of eyes and skin and may cause BURNS and DERMATITIS.	
Case Material	Standard Grade, No hazard in non	UL94:HB & Flame Retardant (FR) Grade, UL94:V0.
Separator Material		

SECTION 3: COMPOSITION / INFORMATION ON INGREDIENTS

Components	Risk Phrases ¹	Substances	Approximate %	Chemical Symbol	CAS No.
Dista Culai	rillases	Metallic Lead	30 to 40	Pb	7439-92-1
Plate Grid	R23	Calcium	< 0.1	Ca	7440-70-2
	R25	Tin	< 2	Sn	7440-31-5
Active	R23	Lead Monoxide	< 0.1	PbO	1317-36-8
Materials	R24	Lead Dioxide (Lead IV Oxide)	35 to 45	PbO ₂	1309-60-0
	R25	Barium compound	< 1.5	Ba	7440-39-3
Battery Electrolyte	R21 R22 R35 R36 R37 R38 R49	Dilute Sulphuric Acid	10 to 20	H ₂ SO ₄	7664-93-9
Case Material		Standard Grade, UL94:HB ABS (Acrylonitrile-Butadiene-Styrene Copolymer)	5 to 10		9003-56-9
		Flame Retardant (FR) Grade, UL94:V0 ABS (Acrylonitrile-Butadiene-Styrene Copolymer)	5 to 10		9003-56-9
		Tetrabromobisphenol-A-diglycygilether, with tribromophenol	< 0.1]	40039-98-8
		Antimony trioxide	< 0.01	}	1309-64-4
Separator Material		Absorbent Glass Matt (AGM) Separator (100% Borosilicate Glass Microfibre)	2 to 5		65997-17-3

For full text of R-phrases see SECTION 16



In accordance with REACH Regulation EC No. 1907/2006

Document:	SDS 01 ·
Issue No:	6
Issue Date:	16-May-2014
Page	3 of 11

SECTION 4: FIRST AID MEASURES FOR ACUTE EXPOSURE

This information is of relevance only if the VRLA Battery has suffered damage, is broken and persons have direct contact with the internal components.

4.1	Description of first aid measures			
	Components		Action	
	Plate Grids and Active materials	Inhalation:	Remove the person from exposure to fresh air. Seek advice from a medical doctor	
,		Ingestion	Wash out mouth with water and give plenty of water to drink. Do not induce vomiting. Seek advice from a medical doctor	
	Table of the state	Skin Contact:	Wash off with plenty of water and soap to prevent accidental ingestion or inhalation Seek medical advice if pain or rash does not reduce	
		Eye Contact:	Immediately infigate with eyewash solution or clean water for at least 10 minutes, noiding the evelids apart. Then take the person to hospital without further delay	
		Self-protection for the first aider	Eye protection (safety glasses or face shield), and heavy-duty gloves are required. In case of inhalation, a face mask or respirator may be required.	
	Battery Electrolyte		SPEED IS ESSENTIAL - OBTAIN IMMEDIATE MEDICAL ATTENTION.	
		Inhalation:	Remove the person from exposure to fresh air. If the person continues to feel unwell seek advice from a medical doctor.	
		Ingestion	Wash out mouth with water and give plenty of water to drink. Do not induce vomiting, If the person continues to feel unwell seek advice from a medical doctor.	
		Skin Contact:	Drench with large quantities of water. Remove contaminated clothing and place in water to dilute the acid Continue to wash the affected area for at least 10 minutes. Seek advice from a medical doctor	
Ì		Eye Contact:	SPEED IS ESSENTIAL - OBTAIN IMMEDIATE MEDICAL ATTENTION Immediately irrigate with eyewash solution or clean water for at least 10 minutes, holding the eyelids apart. Then take the person to hospital without further delay	
A STATE OF THE STA		Self-protection for the first aider	Eye protection (safety glasses or face shield), and heavy-duty gloves are required. In case of inhalation, a face mask or respirator may be required.	
	Case Material	Inhalation:	Material can burn in a fire with toxic smoke and decomposition products. Upon inhalation of decomposition products, keep patient calm, remove to fresh air, and seek advice from a medical doctor. If a large quantity is inhaled take the person to hospital. Note to physician: Treat according to symptoms (decontamination, vital functions), no known specific antidote.	
		Ingestion	Wash out mouth with water and give plenty of water to drink. Do not induce vomiting. If the person continues to feel unwell seek advice from a medical doctor.	
		Skin Contact:	Areas affected by molten material should be quickly placed under cold running water and a sterile protective dressing applied. Seek advice from a medical doctor	
		Eye Contact:	May cause irritation or injury due to mechanical action and traces of Battery Electrolyte. Immediately irrigate with eyewash solution or clean water for at least 10 minutes, holding the eyelids apart. Then take the person to hospital without further delay Eye protection (safety glasses or face shield), and disposable gloves are required.	
		Self-protection for the first aider	In case of inhalation, a face mask or respirator may be required.	
	Separator Material	Inhalation:	Remove patient from exposure to fresh air. If irritation persists, seek advice from a medical	
		Ingestion	Wash out mouth with water and give plenty of water to drink. Do not induce vomiting. If the person continues to feel unwell seek advice from a medical doctor.	
		Skin Contact:	After contact with skin, wash immediately with plenty of soap and water. If imitation	
		Eye Contact:	May cause irritation or injury due to mechanical action and traces of Battery Electrolyte. Immediately irrigate with eyewash solution or clean water for at least 10 minutes, holding the evelide apart. Then take the person to hospital without further delay.	
		Self-protection for the first aider	Eye protection (safety glasses or face shield), and disposable gloves are required. In case of inhalation, a face mask or respirator may be required.	



In accordance with REACH Regulation EC No. 1907/2006

Document:	SDS 01
Issue No:	6
Issue Date:	16-May-2014
Page	4 of 11

SECTION 5: FIRE-FIGHTING AND EXPLOSION HAZARD MEASURES

5	VRLA Battery	General Information	 VRLA Batteries emit hydrogen gas which is highly flammable and will form explosive mixtures in air from approx. 4% to 76%. This can be ignited by a spark at any voltage, naked flames or other sources of ignition. Batteries in use will be part of an electrical circuit and must be isolated from the power source before attempting to put out a fire. Switch the power OFF before disconnecting the batteries from the power source. Damaged batteries may expose negative plates, grey in colour, which may ignite if allowed to dry out. These plates may be wetted down with water after the battery has been removed from all electrical circuits.
5.1		Suitable Extinguisher types:	CO ₂ ; Foam; Dry Powder.
3.1		Unsuitable Extinguisher types	Water extinguishers must never be used to put out an electrical fire.
5.2		Hazardous combustion & decomposition products:	Carbon monoxide, Sulphur Dioxide, Sulphur Trioxide, Lead fume and vapour, toxic fumes from decomposition of battery case materials.
5.3		Advice for fire-fighters	Full face visor or safety goggles; Respiratory equipment or self-contained breathing apparatus (SCBA); Full acid resistant protective clothing must be worn in fire-fighting conditions.

SECTION 6: ACCIDENTAL RELEASE MEASURES
This information is of relevance only if the VRLA Battery has suffered damage and is broken.

Components		
VRLA Battery		VRLA batteries are designed to be safe to handle and not to leak battery electrolyte under normal conditions. In case of accidental damage heavy-duty gloves are required to pick-up the battery to protect against unseen electrolyte leakage
Plate Grids and Active Materials	Personal Precautions:	Eye protection (safety glasses or face shield), and heavy-duty gloves are required. If the material is wet, a face mask or respirator is not required If the material is dry, a face mask or respirator is required
	Clean-up Methods:	Large, solid pieces may be picked up and bagged for recycling. Never use a brush to sweep up debris; it may create Lead-dust in the air. We clean the spill area to remove all traces of debris. Battery debris and cleaning materials must be collected and placed in an inert sealed container (e.g. self-seal plastic bag or bucket) for disposal, see Section 13.
	Environmental Precautions:	Do not allow material to enter a watercourse. Exposed Lead materials must be placed in an inert sealed container (e.g. self-seal plastic bag or bucket) for disposal, see Section 13.
Battery Electrolyte:	Personal Precautions:	Ensure sultable, acid resistant personal protective clothing (including heavy- duty gloves, safety glasses and respiratory protection) is worn during removal and clean-up of spillages.
	Clean-up Methods: Small spillages:	Neutralise and absorb the spillage using soda ash, sodium bicarbonate (available from supermarkets), sodium carbonate or calcium carbonate powder. Wet clean the spill area to remove all traces of debris. Battery debris and cleaning materials must be collected and placed in an inert sealed container (e.g. self-seal plastic bag or bucket) for disposal, see Section 13.
	Large spillages:	Large amounts of electrolyte spillage are unlikely with VRLA batteries since the electrolyte is fully absorbed in the active materials and separator. Bund the spillage area using dry sand, earth, sawdust or other inert material.
		Neutralise the electrolyte using soda ash, sodium bicarbonate (available from supermarkets), sodium carbonate or calcium carbonate powder. Wet clean the spill area to remove all traces of debris and electrolyte. Cleaning materials must be collected and placed in an inert sealed container (e.g. self-seal plastic bag or bucket) for disposal, see Section 13.
	Environmental Precautions:	Battery electrolyte must not be allowed to enter any drains or sewage system or water course.
Case Material:	Clean-up Methods:	Assume battery case material is contaminated and proceed as for Plate Grid and Active Materials above.
Separator Material:	Clean-up Methods:	Assume battery case material is contaminated and proceed as for Plate Grid and Active Materials above.

Note: If appropriate refer to 8 and 13



In accordance with REACH Regulation EC No. 1907/2006

Document:	SDS 01
Issue No:	6
Issue Date:	16-May-2014
Page	5 of 11

SECTION 7: HANDLING AND STORAGE

7.1	Component:	Precautions For Safe	
	VRLA Battery	Handling:	
	·		Only trained operators should be allowed to handle VRLA batteries.
			<u>PPE</u> : No specialist protective clothing or equipment is required, except that for handling heavy weights.
			Hygiene: There are no specialist requirements beyond good, standard workplace practices.
		,	Mechanical lifting aides: (e.g. FLT and pallet trucks) will be required to move pallets of batteries. Weight approximately 1 tonne
	-	·	Mechanical handling aides: (e.g. trucks and lifters) will be required to handle individual batteries over 25 kg in weight.
			General Safety Considerations: Do not drop batteries: dents and deformation of the case may be an indication
			of internal damage to the battery. Cracks will allow electrolyte to escape. Do not place VRLA Batteries ild-to-lid so that terminals will short-circuit.
7.2		Conditions For Safe Storage, Including Any	Store VRLA Batteries in a cool, well-ventilated area with a solid, impervious surface, and adequate containment in the event of accidental acid sollage.
	70m	Incompatibilities:	Store under a roof and protect against direct sunlight and adverse weather conditions including rain, snow and other sources of water.
			Storage of large quantities of VRLA batteries may require approval from local environmental protection agency and/or local water authorities.
			Pallets of VRLA Batteries are heavy. Store at ground level or in lower levels of storage systems (e.g. racking).
			Take special care in dry conditions to avoid the risk of electrostatic discharges.
	7		Protect against physical damage and exposure to organic solvents and other incompatible materials.
			Do not store VRLA batteries close to sources of heat, naked flames and
			sparks. Store batteries in their original packaging wherever possible. When batteries are removed from their original packaging (e.g. for transportation of small quantities), ensure new packaging protects the batteries from damage and the
			risk of short-circuit of the terminals.
		End-of-Life (EC WEEE Regulations)	Ensure batteries are removed from equipment at the end of life and are collected for recycling by an approved contractor.
7.3	-	Specific End Uses: Installation:	Refer to EN 50272-1:2010, Safety requirements for secondary batteries and battery installations – Part 1 General safety information.
			 Refer to EN 50272-2:2001, Safety requirements for secondary batteries and battery installations – Part 2 Stationary batteries.



In accordance with REACH Regulation EC No. 1907/2006

Document:	SDS 01
Issue No:	6
Issue Date:	16-May-2014
Page	ô of 11

SECTION 8: EXPOSURE CONTROL / PERSONAL PROTECTION

	Components		TPERSONAL PROTECTION
8.1	VRLA Battery	Control Parameters:	There are no special control parameters for the handling, storage, installation o VRLA Batteries.
			VRLA Batteries emit hydrogen gas which is highly flammable and will form explosive mixtures in air from approximately 4% to 76%. Never install VLRA Batteries in a gas-tight enclosure during storage, transport or usage.
8.2		Exposure Control:	There are no special exposure controls for the handling, storage, installation or use of VRLA Batteries.
8.3		Personal Protection;	When there is no evidence of damage or visible traces of liquid (electrolyte) or solid deposits on the batteries they may be handled safely without extra personal protective equipment.
			Ensure electrical insulation equipment is used when installing batteries. (e.g. insulated mats and covers; insulated tools)
			Remove ALL metallic objects from the person when working with VRLA Batteries: e.g. Jewellery (rings, watches, bracelets, necklaces), pens, torches, etc.
			Where there are signs of damage or liquid (electrolyte) or solid deposits, rubber gloves and acid resistant clothing must be worn when handling the batteries and affected packaging to protect against the effects of any electrolyte that may be present.
			If it is suspected that free electrolyte is present, then safety glasses must be worn, and if large amounts are present, chemical goggles or face shield should be used.
		UL CAUTIONARY STATEMENT:	"Warning: Risk of fire, explosion, or burns. Do not disassemble; heat above 50°C; or incinerate".

SECTION 9: PHYSICAL AND CHEMICAL PROPERTIES

Components						
VRLA Battery	The main components are listed in SECTION 2 above.					
	 ne undamage 	d product is a manut	actured exticle in an inext pleasi-	c (ABS) case, which will burn if		
	t ampleored to life	n iondeletues of s	DUTCES OF ISBITION SAME NATION	I franco ava mende redste Etter i i en er i i		
	ABS cases, see	technical specificat	ion. These hatteries carry the	r types are made with Flame Retarda suffix 'FR' after the battery type; e.g.		
	NP24-121FR	,		dinx in aller the battery type, e.g.		
information below refers to ublished for reference only	o the physical and ch	emical properties of	the main VRLA Battery compor	nents and substances. This informat		
Plate Grids and	Appearance		Safety-related data			
Active materials	Form	Solid				
ļ	Colour	Grey or brown	Solidification point	327 °C		
-	Odour	Odourless	Boiling point	1740 °C		
	- Jacobs	i Odobiless	Solubility in water			
			Solubility in acid or	Yes, dependant on the strength of		
			elkaline solutions	solution.		
			Density (at 20°C)	11.35 g/cm ³		
Battery Electrolyte:	 		Vapour pressure (at 20°C)	N.A.		
,	Form	Liquid				
	Colour	Colourless	Solidification point	-35 to -60 °C		
	Odour	THE PARTY OF THE P	Boiling point	Approx 108 to 114 °C		
	Odour	Odourless	Solubility in water	Complete		
			Density (at 20°C)	Variable up to 1.350 g/cm ³		
Case Material:	Appearance		Vapour pressure (at 20°C)	N.A.		
	1	0.01	Safety-related data			
	Form	Solid	Softening point	> 100 °C (DIN 53460)		
	Colaur	Grey or black	Flash Point	>330 °C `		
	Odour	Slight Odour	Solubility in water	Insoluble		
			Solubility in other solvents	Soluble in polar solvents, aromatic		
				solvents, chlorinated hydrocarbons		
			Density (at 20°C)	1.07-1.4 g/cm3 (DIN 53479)		
			Vapour pressure	1mm Hg		
Separator Material:			(at 973°C)	-		
osparator material:						
	Form	Fibrous material	Solidification point	N/A		
1	Colour	White	Boiling point	N/A		
	Odour	Odourless	Solubility in water	Insolubie		
			Density (at 20°C)	N/A		
l	<u> </u>		Vapour pressure (at 20°C)			



In accordance with REACH Regulation EC No. 1907/2006

Document:	SDS 01
issue No:	6
Issue Date:	16-May-2014
Page	7 of 11

SECTION 10. STABILITY AND REACTIVITY

	Components		
10.1	VRLA Battery	Stability:	Within the operational temperature range -20 to +50 °C the undamaged product is stable.
10.4	Plate Grids and Active materials:	Materials & Conditions to Avoid:	Powdered Lead reacts violently with fused ammonium nitrate and sodium acetylide. Reacts violently when in contact with chlorine trifluoride.
10.3	Battery Electrolyte:	Possibility of Hazardous Reactions	Dilution of the higher concentrated grades with water may liberate excessive heat. Highly reactive with metals and organic materials. On contact with metals, may generate hydrogen which forms explosive mixtures with air. Destroys organic materials such as cardboard, wood, textiles, etc. Vigorous reaction with sodium hydroxide and alkalis.
10.6		Hazardous Decomposition Product(s):	Sulphur oxides
10.1	Case Material:	Materials & Conditions to Avoid:	To avoid thermal decomposition, do not overheat. Starts to decompose at temperatures >275'C. Powerful oxidising agents.
10.6		Hazardous decomposition products:	Monomers, other degradation products, traces of hydrogen cyanide.
10.1	Separator Material:	Stability:	Stable material.
10.4		Materials & Conditions to Avoid:	Incompatible with Hydrofluoric acid and concentrated Sodium Hydroxide.
10.6		Hazardous decomposition products:	No hazardous polymerisation expected.

SECTION 11: TOXICOLOGICAL INFORMATION This information is of relevance only if the VRLA Battery has suffered damage and is broken

Ingestion:

Components This information does not apply to the undamaged VRLA Battery. It is of relevance if the battery is broken and the components are VRLA Battery released to the environment. Exposure limits may vary according to national law and regulations. Toxic by ingestion or inhalation Plate Grids: Toxicity Metallic Lead, Chronic poison Lead is a poison that affects virtually every system in the body
Symptoms include fatigue, headaches, constipation, aching bones and muscles, gastrointestinal tract disturbances and reduced Lead alloys. appetite Blood Lead levels of 80 µg/di and above have been associated with both acute and chronic effects of Lead poisoning Toxic by ingestion or inhalation Active materials: Toxicity Lead dioxide. · Chronic poison Chronic exposure to Lead compounds may lead to a build-up of Lead in the body, giving rise to a variety of health problems, including anaemia, kidney and liver damage, impaired eyesight, memory loss and CNS² damage Corrosive, the more concentrated solutions can cause serious burns Battery Electrolyte: Dilute Sulphuric Acid to the mouth, eyes and skin Harmful by Ingestion and through skin contact Mist is a severe irritant to the respiratory tract. Fluid build up on the Inhalation: lung (pulmonary cedema) may occur up to 48 hours after exposure and could prove fatal

² CNS = Central Nervous System

If this document is printed, it is to be considered uncontrolled and for reference only.

gastrointestinal tract

Will immediately cause severe corrosion of and damage to the



In accordance with REACH Regulation EC No. 1907/2006

Document:	SDS 01
Issue No.	6
Issue Date:	16-May-2014
Page	8 of 11

11,1	Battery Electrolyte:	Skin Contact:	Causes severe chemical burns
		Eye Contact:	Risk of serious damage to eyes. Causes severe burns. May cause prolonged or permanent damage or even total loss of sight. Mist will cause irritation
	Case Material:		According to information available the product is not harmful to health provided it is correctly handled and processed according to the given recommendations.
£	Separator Material:		Based on animal implantation and epidemiologic studies glass microfibers are thought to have some limited carcinogenic potential and as such are designated as Group 2B materials (IARC, US). The material should be treated as a category 3 carcinogen (Europe). Limited evidence of carcinogenic effect.

SECTION 12: ECOLOGICAL INFORMATION
This information is of relevance only if the VRLA Battery has suffered damage and is broken.

	Components		
12.1	VRLA Battery		This information does not apply to the undamaged VRLA Battery. It is of relevance if the battery is broken and the components are released to the environment.
12.2	Plate Grids and Active materials:	Metallic Lead, Lead alloys and Lead dioxide.	Chemical and physical treatment is required for the elimination of Lead from water. Waste water containing Lead must not be disposed of in an untreated condition.
		Ecotoxicity: Risk Phrase R52/53	The general classification for Lead compounds, R50/53 does not apply to Battery Lead Oxide Tests in 2001 and 2005 have concluded that Battery Lead Oxide is NOT toxic for the environment; neither R50 nor R50/53 nor R51/53. Risk Phrase R52/53 (Harmful to aquatic organisms, may cause long-term adverse effects in the aquatic environment) applies to Battery Lead Oxide.
		Effect in the aquatic environment:	Toxicity for fish: 96 h LC 50 > 100 mg/l Toxicity for daphnia: 48 h EC 50 > 100 mg/l Toxicity for alga: 72 h IC 50 > 10 mg/l
12.3	Battery Electrolyte:	Ecotoxicity:	 In order to avoid damage to the sewerage system, the acid has to be neutralised by means of soda ash, sodium bicarbonate or sodium carbonate before disposal. Ecological damage is possible by change of pH. The electrolyte solution reacts with water and organic substances, causing damage to flora and fauna. The electrolyte may also contain components of Lead that can be toxic to aquatic environments.
		Persistence and Degradation:	Remains indefinitely in the environment as sulphate.
12.4	Case Material:	Elimination information:	No data available: insoluble in water
		Behaviour and environmental fate:	Due to the consistency of the product, and its insolubility in water, it will apparently not be bio-available.
12.5	Separator Material:		No data available: insoluble in water Not thought to pose any risk to the environment.

SECTION 13: DISPOSAL CONSIDERATIONS

Components		
13.1 VRLA Battery	Europe:	Spent (used) VRLA Batteries are subject to the requirements of the Batteries Directive 2006/66/EC on batteries and accumulators and waste batteries and accumulators. Spent (used) VRLA Batteries MUST be sent for recycling through an authorised contractor at the end-of-life. The WEEE Directive 2002/96/EC (Waste Electrical and Electronic Equipment) applies. Spent (used) VRLA Batteries MUST be removed from electrical and electronic equipment at the end-of-life.



In accordance with REACH Regulation EC No. 1907/2006

Document:	SDS 01
Issue No:	6
Issue Date:	16-May-2014
Page	9 of 11

		Worldwide:	VRLA batteries contain inorganic Lead compounds and Sulphuric Acid which are damaging to the environment. Spent (used) batteries must be disposed of in an environmentally friendly manner in accordance with local national laws and regulations. VRLA batteries must not be dismantled, burnt or incinerated as a means of disposal. At the end of life VRLA batteries may still be electrically 'live' and contain a large amount of electrical energy. The same care and attention to safe handling should be taken as when handling new batteries. Particular care must be taken to avoid short-circuiting the battery terminals.
13.2	Plate Grids and Active materials:	Europe Worldwide	Metallic Lead and active materials (Lead Oxides) must be recycled. Disposal must be carried out in accordance with the European Hazardous Waste Directive 2008/98/EC
13.3	Battery Electrolyte:	Europe	Disposal must be carried out in accordance with the European Hazardous Waste Directive 2008/98/EC on the protection of the environment through criminal law
		Worldwide	Disposal should be in accordance with local, state or national legislation.
		General	Battery electrolyte is dilute Suiphuric Acid, the strength of which depends on the state of charge of the batteries. It must be neutralised before disposal. See SECTION 6 for clean-up and disposal advice.
13.3	Case Material:		Do not dispose of this product into sewers, any ocean or water course in order to prevent marine animals and birds from ingesting. Recycling is encouraged. Disposal by controlled incineration or source landfill in accordance with local national laws and regulations may be acceptable.
13.4	Separator Material:		 Constitutes a special waste by virtue of hazardous substance content. Dispose of via approved landfill site. Disposal by controlled source landfill in accordance with local national laws and regulations may be acceptable.

SECTION 14: TRANSPORT INFORMATION

Components	·	
14.1 VRLA Battery	Land Transport	Land Transport (ADR / RID)
*		• UN N°: UN2800
		Classification ADR / RID: Class 8
		 Proper Shipping Name: BATTERIES, WET, NON-SPILLABLE electric
İ	1	storage
		Packing Group ADR: not assigned
		Tunnel code: E
		 ADR / RID: New and spent (used) batteries are exempt from all ADR /
	ŀ	RID (special provision 598)
	Sea Transport	Sea transport (IMDG Code)
1	·	• UN Nº: UN2800
		Classification: Class 8
		 Proper Shipping Name: BATTERIES, WET, NON-SPILLABLE electric
		storage
		• EmS: F-A, S-B
		Non-Spillable batteries meet the requirements of Special Provision 238;
1		they are therefore exempt from all IMDG codes and are not subject to
	1	special regulation for sea transport
	Air Transport	Air Transport (IATA-DGR)
1		• UN Nº: 2800
1		Classification: Class 8
1		 Proper Shipping Name: BATTERIES, WET, NON-SPILLABLE electric
ŀ		storage
		 Special Provision A48: Packaging test are not considered necessary
		 Special Provision A67: Yuasa's VRLA batteries meet the requirements
İ		of Packing Instruction 872.
		The battery has been prepared for transport so as to prevent:
ļ		 a) A short-circuit of the battery's terminals by packaging in a strong an
		sturdy carton box; AND/OR
		b) The battery has been fitted with an insulating cover (made from AB)
		which prevents contact with the terminals.
		c) Unintentional activation is thus prevented
,		The words "NOT RESTRICTED" and the Special Provision (SP) numb
		must be indicated on all shipping documents
	1	 Special Provision: A164: The battery has been prepared for transport
1		as to prevent:

If this document is printed, it is to be considered uncontrolled and for reference only.



In accordance with REACH Regulation EC No. 1907/2006

	Document:	SDS 01	
	Issue No:	6	
į	Issue Date:	16-May-2014	
	Page	10 of 11	

		Short-circuit of the battery's terminals by packaging in a strong and sturdy carton box; AND/OR The battery has been fitted with a cover (made from ABS) which prevents contact with the terminals Unintentional activation is thus prevented
	All methods of transport	DO NOT PLACE VRLA BATTERIES INSIDE SEALED OR GAS-TIGHT ENCLOSURES. VRLA Batteries emit hydrogen gas which is highly flammable and will form explosive mixtures in air from approximately 4% to 76%. This can be ignited by a spark at any voltage, naked flames or other sources of ignition.

SECTION 15: REGULATORY INFORMATION

	Components.		
15.1	VRLA Battery	Regulred Markings:	
		X	Crossed-out wheeled bin indicating "SEPARATE COLLECTION" for all batteries and accumulators. Not to be disposed of with general domestic, commercial or industrial waste. Ref: The Batteries Directive 2006/66/EC
		Pb	The Pb symbol indicates the heavy metal content of the battery and enables the Lead-Acid battery to be sorted for recycling. Ref: The Batteries Directive 2006/66/EC.
		80	The International Recycling Symbol, required by law in many countries world-wide to facilitate the identification of secondary batteries and accumulators for recycling. Ref. IEC 61429: 1995, Marking of secondary cells and batteries with the International Recycling Symbol ISO 7000-1135.
		EC Directives	Directive 2006/66/EC, on batteries and accumulators and waste batteries and accumulators Paragraph (Recital) 29 states: "Directive 2002/95/EC of the European Parliament and of the Council of 27 January 2003 on the restriction of the use of certain hazardous substances in electrical and electronic equipment does not apply to batteries and

SECTION 16: OTHER INFORMATION

	Components		
16 (a)	Revision Information	Version 4: February 2013 There has been a major revision of all sections of the Safety Data Sheet to bring it into line with current REACH Regulations.	
16 (b)	Abbreviations	Pb - The chemical symbol for Lead Ba - the chemical symbol for Barium Ca - the chemical symbol for Calcium Sn - the chemical symbol for Tin PbO ₂ - the chemical formulae for Lead Dioxide H ₂ SO ₄ - the chemical formulae for Sulphuric Acid VRLA - Valve Regulated Lead-Acid battery	
16 (c)	Key literature references and sources of data	SDS documents from suppliers for components and raw materials	
16 (d)	CLP Regulations	Not Applicable	
16 (e)	e) Risk Phrases	R21	Harmful in contact with skin
		R22	Harmful if swallowed
		R23	Toxic by inhalation
		R24	Toxic in contact with skin
		R25	Toxic if swallowed
		R35	Causes severe bums
		R36	Irritating to eyes
		R37	Irritating to respiratory system
		R38	Irritating to skin

If this document is printed, it is to be considered uncontrolled and for reference only.



In accordance with REACH Regulation EC No. 1907/2006

Document:	SDS 01
Issue No:	6
 Issue Date:	16-May-2014
Page	11 of 11

		R49	May cause cancer by inhalation
		R52	Harmful to aquatic organisms
		R53	May cause long-term adverse effects in the aquatic environment
16 (f)	Training Advice	Only trained, competent personnel, who have received special instructions for the hazards and risks, should be allowed to handle VRLA Batteries. See Section 7.1 for general advice	
16 (g)	Further Information	··· ···	