



Certificate number: 2106704

Date issued 3rd June 2021

Date expired 2nd June 2026 Original/Amendment Original

Kiwa UK Regulation 4 (KUKreg4) Approval

ATS3 – Without Production Surveillance

Issued by Kiwa Watertec (UK)

Evaluation Guideline: Kiwa UK – EG004
Reference Standards: Regulators Specification
Model Designations: see Appendix

Factor: Norcros Group (Holdings) Limited T/A Abode.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied on to comply with the above Evaluation Guideline and Standards, and can be marked with the KUKreg4mark.

The intended use of this certificate is for compliance with Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales; 2009 Northern Ireland and 2014 Byelaws Scotland

This certificate has been issued in accordance with the Kiwa regulations for product certification

Signed on behalf of Kiwa Watertec

David Jay,
Business Unit Manager – Authorised Signatory
Kiwa Watertec

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate issued to:
Norcros Group (Holdings) Limited T/A Abode
Unit L, Zenith Park
Whaley Road
Barnsley
S75 1HT



UK Approval Certificate (page 2 of 2)

Appendix to Certificate 2106704

The following products are covered by this certificate -

PRODUCT DESCRIPTION NICO range of single hole, single outlet (swivel) combination tap assemblies (chromium plated brass). Incorporating ceramic cartridge headworks and single lever operating members. The spout outlet incorporates a plastic aerator. ATS3 – Without Production Surveillance.
MODEL(S) ACT3034, ACT3035.
SIZE: Stainless steel braided EPDM lined hose assembly incorporating ½" captive nut end connections.
SCOPE: Manufacturer recommended maximum working pressure 5.5 Bar & maximum operating temperature 60°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 60°C. Deck Mounted.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES If this tap or combination tap is installed so that its base is no lower than the spillover level of the receiving vessel a Type AUK3 air gap is achieved. Consider balanced supplies or appropriate backflow protection at the inlets.
MARKING CAL on body.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes